

**Date: 11.01.2023**

S No.	Tender Reference / clause	Query/Clarification of prospective bidders	Clarifications to the bidder query
1	Delivery Location	Consignees/Reporting Officer at Mumbai & in SOW document, it is Hyderabad. What is the exact location where batteries to be delivered	All 552 no's of battery to be delivered at Bank's Hyderabad location.
2	Eligibility / General	Authorization should be Tender Specific OR General Authorization	Please refer <b>Annexure 07 - Letter of Undertaking from OEM</b> as mentioned under ATC document
3	Eligibility Criteria	OEM Turnover (ATC)	OEM need to fulfil the turnover criteria as mentioned under ATC document.
4	Eligibility Criteria	Is local registered office is mandatory. We do have local Service Engineers to provide service	Bidder / OEM either of them must have local office in Hyderabad as mentioned under ATC document under Annexure 01
5	EMD	Clarification for exemption of submitting EMD for GeM vendor assessed	Only MSEs / Startups are exempted from EMD.
6	General	Our EnerRocket SMF VRLA Batteries are manufactured Made in Vietnam. Batteries does not have and local Content. Kindly confirm we are eligible to participate.	Bidder / OEM who fulfil the eligibility conditions can participate in this tender.
7	Scope	Need clarifications regarding Batteries Sizing and whether batteries are to be replace are in only one site or Different sites.	The make & model of all existing Batteries are mentioned in the ATC document. Batteries to be replaced are at single location only.
8	Scope	For suitability checking for battery of AGM or Gel battery & also cable rating	The batteries should be either AGM / Gel or AGM +Gel batteries. Specification of batteries required are mentioned under ATC document.
9	Scope	For calculation of rack dimension	Dimensions of all existing racks are given under ATC document.

S No.	Tender Reference / clause	Query/Clarification of prospective bidders	Clarifications to the bidder query
10	Scope	In case of new rack is supplied, is the existing rack shall be returned to vendor.	Bidder should strive to use the existing racks available at the Bank site. Else they may have to replace existing racks with new one of similar quality without any additional cost to Bank
11	Scope	We want to know designed Back up time in Minutes for each UPS considering full load. In data absence we will consider 10 Mins.	No change. Refer specification of batteries given in the ATC document

All other Terms and Conditions of the bid shall remain same.