

Corrigendum No-1 dated 02.05.2022

E-Tender No.	BCC/FM/114/46
Details	Major External/Internal repair works at Bank's Residential and Commercial Building – Sharda Bhawan, JVPD, Vile Parle West, Mumbai

Query	Reply / Amendment
1. Firms/agencies claiming exemption from submission of EMD under any statutory authority/law.	The firm must submit valid registration certificate (NSIC, MSME, KVIC etc) on e-tender.
2. Price bid item no 15 Excavation the entire boundary wall of the building 3' to 4' ft. and 6" width on all the boundary sides of the building then treating the wall and floor with membrane coat 3' to 4' ft. below and 2'-0" above all entire boundary wall of the building. Then filling up the excavated portion properly to receive the PVC .	To be read as: Excavation along the entire periphery of building upto 4' height and width upto 6' (as per site requirement) as directed by the Architect and then treating the wall and floor with membrane coat 4' ft below and 2'-0" above the ground level. The excavated portion then to be filled up properly to receive PCC. Make of membrane- Dr. Fixit, Asian Paints, STP (Shalimar Tar Product) Or Equivalent (3 mm thickness)

All the other terms and conditions of the tender will remain unchanged.

- All bidders are advised to consider the above points while submitting the financial bids.
- The above shall be complementary in contents with the existing terms and conditions of the tender except otherwise explicitly superseded. Other terms and conditions of the tender shall remain unchanged. Bidders have to meet requisite criteria laid down in the tender for qualification
- This addendum/corrigendum shall form part of the tender i.e. contract agreement. The same shall be treated as acceptance of those conditions without any modifications and submitted along with the Tender bid. Non acceptance of the Addendum by the Bidder or adding any other condition shall be treated as conditional Tender and price bid of such Tenderers shall not be opened.

The last date of online submission of the Tender bids extended to **06/05/2022** upto **15:00 hrs** and technical bid shall be opened on the same day at **15:30 hrs**.

Asst General Manager
Facilities Management
Baroda Corporate Centre
Bank of Baroda