BANK OF BARODA

ADDENDUM 1

Dated – 08.06.2023

TENDER PERIOD FROM 20.05.2023 TO 21.06.2023 UPTO 2:00 PM

PRE-BID MEETING ON 31.05.2023 AT 12:00 AM

OPENING OF TECHNICAL BID ON 21.06.2023 AT 4:00 PM

ADDENDUM – 1

Notice inviting tender for Design, supply, installation, testing and commissioning of Roof Top Solar Plant at Baroda Apex Academy Building at Ahmedabad.

SR. NO.	Bidder Quarry	Tender Script	To be read as / Addendum
1.	In technical Specification it is mentioned that PV Panel should be of Poly-crystalline, but as per market scenario for 520 Wp only monocrystalline Panels available. Please clarify.	Section – 2, Page no. 2, Panel Type: Poly Crystalline	Shall be reads as Panel Type : Monocrystalline (please refer Section -2 , revised technical specification)
2.	Bidder Requested for sectional elevation of proposed system for their reference in accordance to the metering space, panel room	-	Please refer attached drawings as • Sectional elevation of proposed solar roof top plan • Site development for meter installation space. • Upper basement for Panel room location.
3.	For the approval of roof top solar system & for the commissioning of the same, it is necessary to have install different pre-tested / certified meters as per guidelines along with necessary electrification. Please elaborate the scope of work in relate of this.	-	In the event of commissioning as it is necessary to installed the pre-tested and certified meter from the power supply authority, bidder must note scope of works as follows. • All the required meters **(max total load 1000 kw)** shall be provided by the bidder only without claiming any extra costs to the bank. • Bank shall reimburse the amount of actual cost of statutory fees paid by vendor to the authority upon production of original payment receipt to the bank.

			Bank will not pay any additional expenses towards the approval for the charge of the panel without such documents. • Obtaining all statutory approval shall be in the scope of contractor, no extra/additional payment shall be made by the bank for the same. • All the necessary electrification i.e., cable connection and termination up to panels, meters shall be borne by the bidder.
4.	Bidder requested to provide NOC from the Bank before application of the solar panel connection to the grid & not to consider delay if bank has not arranged such documents required for statutory approvals.	-	Bank shall provide all the required documents for the final connection / charge & commissioning of the installed panels. However, bidders bounded for the approval of the commissioning of the same within 30 days from the submission of all requested documents by the bidder. Meantime, it is bidder responsibility to complete all the work including installation, connection to the energy meter / panels / other related works, testing within given time frame.
5.	As per current layout shown in gazebo type, is it necessary to do design as per tender drawing.	All the panels show gazebo type roof top solar having seating facilities below.	As per tender terms, its is in the scope of bidder to submit shop drawing of proposed system. Also, they can optimize space utilization provided that seating arrangement shall be maintained as per proposal & as mentioned under sectional elevation drawing that 2.4m clear heigh should be maintained at lower part of solar panel. Please refer attached drawings.
6.	Tender Submission Method.	-	As per annexure – A (Attached separately)

7.	Technical Specifications	Section-2	Refer attached revised section 2
8	Automatic cleaning system for solar panel required or not?	Section-2 & Section-6-(Price bid)	Not required. Please quote the rate accordingly.

The above shall be complementary in contents with the existing terms and conditions of the tender accept otherwise explicitly superseded. Other terms and conditions of the tender shall remain unchanged.

This addendum-1 shall form part of the tender i.e. contract agreement. The same shall be sealed and signed as acceptance of those conditions without any modifications and submitted along with the Tender bid. Non-acceptance of the Addendum by the Bidder or adding any other condition shall be treated as conditional Tender and price bid of such Tenderers shall not be opened.

Bidders are required to sign all the pages of this addendum-1 and upload along with the transmittal section.

All other terms and conditions mentioned in the tender document shall remain unchanged.

Enclosures with Addendum-1

- Annexure – A (Tender Submission Method)
- Drawing of Upper basement /Ground Floor Electrical layouts / Terrace Plan & sectional elevation
- Revised Section 2 (Technical Specification)

The last date for submission of tender is extended up to 21/06/2023 @ 2:00 PM. The technical bid shall be opened on 21/06/2023 @ 4:00 PM

Bidders' submission in hard copies before stipulated submission period, i.e. 21/06/2023 up to 2:00 pm at communication address mentioned in Page-2 of Section-1 of Technical Bid by Registered AD/ Speed Post/ Courier/ Post or bidder's has to drop their tender in the tender box available on -Bank of Baroda, Baroda Apex Academy, **Ground floor,GH-4,Nr. Udyog Bhavan, Sector- 11, Gandhinagar -382011,** Gujarat.

Annexure – A (Tender Submission Method)

Tender should consist of two envelopes consisting of following:

1. **Cover 1 - Part – I Seal & sign Technical Bid including prequalification documents and EMD (Earnest Money Deposit receipt)**
2. **Cover 2 - Part – II Price Bid (A).**

Cover 1 - Vol /Part – I Technical Bid shall contain following documents

- Earnest Money Deposit (EMD) receipt online through NEFT/RTGS. NSIC/MSME shall be Exempted for EMD on Submission of Valid Certificate.

Sr. No.	Project Name	EMD (In Rs.)
1.	Notice inviting tender for Design, supply, installation, testing and commissioning of Roof Top Solar Plant at Baroda Apex Academy Building at Ahmedabad.	Rs. 30,000/-

- Technical bid accepting all terms and conditions of the tender along with Annexure A.
- Revised Technical specifications Section-2
- Documents to satisfy Prequalification Criteria.

Cover 2 - Vol/Part – II Price Bid

- **BOQ with rates without any condition. Conditional offers will be summarily rejected.**

Note:

- The tender not accompanied with earnest money deposit receipt / UTR will be summarily rejected and their tender will not be opened.
- Part – I, Part – II of the tenders duly filled in and signed should be submitted in two separate sealed covers.
- Price Bid should contain BOQ with rates without any condition.

The bidders should clearly write on cover-2 the words-

"PRICE BID –COVER 2- "Notice inviting tender for Design, supply, installation, testing and commissioning of Roof Top Solar Plant at Baroda Apex Academy Building at Ahmedabad."

Two Envelopes (i) Technical Bid & Technical specifications cover-1 (ii) Price bid- Cover -2 should be placed in another single cover and super scribed "Notice inviting tender for Design, supply, installation, testing and commissioning of Roof Top Solar Plant at Baroda Apex Academy Building at Ahmedabad" and submitted at following address:

To,
The Head (Apex Academy),
6th Floor,GH-4,Nr. Udyog Bhavan, Sector- 11,
Gandhinagar -382011,
Gujarat