TERRACE FLOOR LAYOUT

SECTION 01

SOLAR NOTES-

1)SOLAR PLANT PROVISION IS TENTATIVE AND FOR REFERENCE ONLY.
2)ACTUAL PLACEMENT AND QUANTITY WILL BE DECIDED AT LETTER STAGE WITH ACTUAL DIRECTION DATA AND SHADOW DETAILS OF SURROUNDING AREA.
3)PLUMBING TAP POINT REQUIRED NEAR BY SOLAR PANEL FOR SOLAR PANEL WASHING.
4)Solar Inverter Location on terrace and Meter location will be near to substation/Torrent Meter Room. Refer Site plan.
5)Solar Panel Structure Height should be minimum 2400mm From FFL of Terrace.

NOTE :-

THIS DRAWING IS THE PROPERTY OF JHAVERI ASSOCIATES SHALL NOT BE USED FOR ANY OTHER PURPOSE WITHOUT OBTAINING PRIOR PERMISSION.
IN CASE THERE IS ANY DISCREPANCY BETWEEN ARCHITECTURAL DRAWINGS AND OTHER DRAWINGS, ARCHITECTURAL DRAWINGS SHALL BE FOLLOWED.
THE DISCREPANCY SHALL BE BROUGHT TO THE NOTICE OF THE CONSULTANT BEFORE COMMENCEMENT OF THE WORK.
THIS DRAWING IS FOR ELECTRICAL DETAILS ONLY.
REFER STRUCTURE DWG / DETAILS FOR CONSTRUCTION EXECUTION.

Notes:

1. ALL GENERAL SWITCH BOARD 150MM AWAY FROM WALL EDGE.
1. TYPE OF WIRING CONCEALED WIRING CONDUIT LAYOUT MAY BE CHANGE AS PER SITE CONDITION AFTER APPROVAL OF CLIENT/CONSULTANT.
2. 9" THICK WALL REQUIRED FOR ALL DB ALL DIMENSION ARE IN METER, UNLESS MENTIONED
3. FAN BOX MUST BE CASTE IRON
4. ANY MAKE OF MATERIAL APPROVE FROM ELECTRICAL CONSULTANT ONLY
5. CONTRACTOR HAS TO PUT JUNCTION BOX WHERE EVER REQUIRED WITH PRIOR PERMISSION OF ARCHITECT OR CONSULTANT.
6. CABLE TRAY TO BE LAID AT BEAM BOTTOM. REQUIRED CLEARANCE OF 150 MM FROM BEAM BOTTOM.

ELECTRICAL LEGEND

LEGEND	DESCRIPTION
TT	34W LED TUBE LIGHT POINT
FTL	FOOT LIGHT POINT
CCL	CEILING LIGHT POINT
CL	CEILING LIGHT POINT
BL	BRACKET LIGHT POINT
SB	SWITCH BOARD
P	6A PLUG POINT WITH 6A SWITCH
PP	6/16A PLUG POINT WITH 16A SWITCH
PP	16A PLUG POINT WITH 16A SWITCH
WS	2NOS 6/16A PLUG POINT AND 1no 16A PLUG POINT WITH 16A SWITCH
F/FH	CEILING FAN POINT WITH FAN BOX & HOOK
EF	EXHAUST FAN WITH PLUG
DB	DISTRIBUTION BOARD (ELECTRICAL)
AC	SPLIT AC
TP	TELEPHONE POINT
TV	TELEVISION POINT
	ELECTRICAL CONTROL
SB	EMERGENCY SWITCH BOARD
P	EMER. 6A PLUG POINT WITH 6A SWITCH
CL	EMERGENCY CEILING LIGHT POINT
	EMERGENCY ELECTRICAL CONTROL
1P	1Ø POWER PLUG POINT WITH SWITCH (1Ø)
3P	3Ø POWER PLUG POINT WITH SWITCH (3Ø)

FOR TENDER(reference only)
DATE : 18/05/2023

PRINT ISSUED FOR

NO.	DATE	DESCRIPTION	DRG.BY	CHK.BY
R0	05/05/2023	ISSUED FOR TENDER	AM	VG

ARCHITECT:

SACHIN GANDHI & ARCHITECTS
Office : "Dev" 148/1/B, Mufti Bungalows, opposite Navjivan Press, Income-Tax Ahmedabad - 380009.
Mobile No.:
Ph.: +91 90999 41399
+91 79 27540541/42
Fax: +91 79 26540544
W: www.sachingandhiassociates.com
E: info@sachingandhiassociates.com

PROJECT NAME:
BOB_LAW_GAREDN

DRAWING TITLE:
ELECTRICAL LIGHTING LAYOUT FOR TERRACE FLOOR PLAN

DRG. NO.	B_TERR-LTG_01	REV. NO.	R0
DATE:	18/05/2023	DRAWING :	AM
SCALE:	NTS	CHECKED BY :	VG

MEP CONSULTANT

JHAVERI ASSOCIATES
2ND Floor, "B" Block, Titanium Business Park
Near Makarba Underbridge, Makarba, Ahmedabad-380051
Tel: 9879508949 Email: info@jhaveriassociates.com
www.jhaveriassociates.com