

**Corrigendum No-1 dated 19.01.2024**

|                     |  |
|---------------------|--|
| <b>E-Tender No.</b> | <b>BCC/FM/MB/115/895</b>   |
| <b>Details</b>      | <b>TENDER FOR PROPOSED 125KW ROOFTOP SOLAR POWER PLANT FOR BANK OF BARODA. MMO BUILDING NOS.1,2 &amp; 3 AT 17 HORNIMAN CIRCLE, FORT, MUMBAI 400 023.</b> |

| <b>Sr. No.</b> | <b>Query</b>   | <b>Reply / Amendment</b>  |
|----------------|--|---|
| 1.             | Sanctioned Load details of existing Electricity Connections  | There are -3- Nos. of 3 Phase connections available with sanctioned loads of 73.50 KW, 60 KW & 26.77 KW and contract demand- 91.87 KVA, 75KVA and 33.46 KVA respectively.   |
| 2.             | Minimum Solar Power Generation per annum Requirements        | 1,60,000 units (One Lakh sixty thousand units per annum). If the Solar Power generation fall more than 10% of Minimum Solar Power Generation per annum (i.e less than 1,46,000 units), AMC annual charges shall be deducted to equivalent amount of difference between actual Power generation and 1,46,000 unit for that particular year including Defects Liability Period.   |
| 3.             | Structural Stability Report of Solar Power System structure. | The Successful Bidder has to obtain Structural Stability Report at their own cost and submit to the Bank / Consultant.  |
| 4.             | Periodic Cleaning of Dust in Solar Panels                    | The Successful Bidder shall arrange for cleaning of Dust on the Solar Panels minimum Bi-Monthly and ensure that the methodology of cleaning are as per the industry practice.   |
| 5.             | Page No.5, Point 8 : EMD in Figures & Words                  | To be read as: Rs.68,250/- (Rupees Sixty Eight Thousand Two Hundred and Fifty only.)  |
| 6.             | Comprehensive AMC scope                                      | The scope of the bidder for 5 Years AMC is as follows: - <ul style="list-style-type: none"> <li>• Minimum Three Preventive maintenance check on system performance annually.</li> </ul> <p>(Checking Inverter functionality &amp; diagnosing abnormal behaviour in the power plant, reducing downtime if any. Assessing Electrical checks, loose connections, string current, voltage, etc. checking on all the terminations, joints,</p> |

|    |  |   |
|----|--|---|
|    |  | <p>AC side and DC side connections. Clearing vegetation, shading from nearby trees, plants etc.)</p> <ul style="list-style-type: none"> <li>• Free call out in the event of any issues / trouble shooting or any complaint.</li> <li>• An app to help monitor the performance of solar system.</li> <li>• Long-term maintenance planning with equipment manufacturers or contractors and assistance in warranty claims. Also to notify manufacturing faults, Management of repairs/upgrades.</li> <li>• Periodic cleaning of the solar panel by the Contractor to achieve above mentioned minimum power generation i.e. 1,60,000 units (One Lakh sixty thousand units) per annum.</li> <li>• Maintenance Manual for Solar Plant to be provided by Contractor after completion of the Installation.<br/>Note: - Consider the periodic cleaning of the solar panel as included in the AMC Rates.</li> </ul> |
| 7. | Electrical Safety and equipment health check by the third party Annually | Electrical safety audit and health check of the solar power systems should be carried out by BEE certified energy Auditor/Chartered Electrical Engineer. The Cost shall be borne by the Contractor.   |
| 8. | Page No. 98: Approved Make for AC DB and DC DB                           | SCHIEDLER to be read as Schneider.  |
| 9. | Skill India  | <p>As per the advisory received from the Ministry of Skill Development &amp; Entrepreneurship, Government of India you are required to engage formally certified skilled workforce or ensure that all your workers would be skilled through Recognition of Prior Learning (RPL) within 2 months from the date of commencement of work under this order at your risk and cost.</p> <p>This may also include a dedicated drive by carrying out RPL in mission mode for your existing skilled workers who are working without any formal certification. Necessary support/guidance shall be provided by the Ministry of skill development and Entrepreneurship by arranging and organizing special RPL camps and skill certification. Confirmation on complying above directive may be</p>   |

|  |  |  |
|--|--|--|
|  |  | conveyed to Bank at regular intervals (quarterly) for reporting to the Ministry concerned accordingly. |
|--|--|--|

**All the other terms and conditions of the tender will remain unchanged.**

- All bidders are advised to consider the above points while submitting the financial bids.
- The above shall be complementary in contents with the existing terms and conditions of the tender except otherwise explicitly superseded. Other terms and conditions of the tender shall remain unchanged. Bidders have to meet requisite criteria laid down in the tender for qualification.
- This addendum/corrigendum shall form part of the tender i.e. contract agreement. The same shall be treated as acceptance of those conditions without any modifications and submitted along with the Tender bid. Non acceptance of the Addendum by the Bidder or adding any other condition shall be treated as conditional Tender and price bid of such Tenderers shall not be opened.

The last date of online submission of the Tender bids will remain unchanged i.e. 01.02.2024 upto 3.00 PM. Bidders are advised to refer/check Bank's website for any additional instruction/addendum/corrigendum before tender submission time.

-----sd/-----

Asst. General Manager  
Facilities Management  
Baroda Corporate Centre  
Bank of Baroda

19.01.2024