

REQUEST FOR PROPOSAL FOR SHORTLISTING OF SERVICE PROVIDER FOR ANNUAL MAINTAINANCE CONTRACT OF FIRE HYDRANT AND SPRINKLER SYSTEM INSTALLED AT BARODA SUN TOWER, BKC, MUMBAI

(RFP Reference: BCC/SEC/110/S-18/585 Dated: 17th October 2018)

ADDENDUM Dated: 02/11/2018

We refer to the Pre-Bid Meeting held at our Baroda Corporate Center, BKC, Mumbai on 29th October 2018 at 1400 hrs wherein queries were raised by the prospective bidders communicated to us through email.

Accordingly, the addendum for the RFP reference BCC/SEC/110/S-18/585 dt: 17th October 2018 is as under:

S.No.	Vendor	Query	Bank's Clarification
1	Target Safety	EMD to be exempted for MSME registered firm.	MSME Registered Company would be exempted from EMD.
2	Products & Services	Whether the Annual Maintainance Contract is Comprehensive or Non-Comprehensive.	The AMC will be Non-Comprehensive
3	Nortex Fire Equipments Co. Pvt. Ltd.	As per the new guidelines, for issuance of Form – B Fire Doors would be under AMC.	Fire Doors are included as part of Tender.
4		No. of Butterfly valve and Gate Valve.	Butterfly Valve – 57 Nos. Gate Valve – 5 Nos.
5		Hydrant & Sprinkler Pump's Manufacturer	Kirloskar Brothers
6		Pump Suction is Negative or Positive.	Positive Suction

You are advised to take note of the above points while submitted the RFP. If required, the interested bidders may visit the site before submitting the bids.

The above shall be complementary in contents with the existing terms and conditions of the RFP except otherwise explicitly superseded. Other terms and conditions of the tender shall remain unchanged.

The addendum shall form part of the RFP. The same shall be sealed and signed as acceptance of those conditions without any modifications and submitted along with the Bid. Non-Acceptance of the Addendum by the Bidder or adding any other condition shall be treated as conditional RFP and will not be considered, hence rejected.

BCC/SEC/110/S-18/ 647

Dated: 02/11/2018