

Clause in RFP

Sr No.	Clause in RFP	Clarifications/ Changes made
1	<p>Annexure 2 – Eligibility Criteria C. Others</p> <p>2. The SP should have at least two of the below certifications / compliance document:</p> <p>a) ISO 27001 or BS 7799–3 Certified (Compulsory) b) NFPA 70 & 75 c) IS 1893:1984 Seismic Compliance d) TIA 942 compliance (for at least two of the following – Architectural, Electrical, Cooling and Network.)</p>	<p>Annexure 2 – Eligibility Criteria C. Others</p> <p>2. The SP should have at least two of the below certifications / compliance document:</p> <p>a) ISO 27001 or BS 7799–3 Certified (Compulsory) b) NFPA 70 & 75 c) IS 1893:1984 Seismic Compliance d) TIA 942/ Uptime Institute compliance (for at least two of the following – Architectural, Electrical, Cooling/ Mechanical and Network/Telecommunication.)</p> <p>In case any of above certification is in progress, bidder has to provide undertaking that they will submit the certificates by December 2021. However, Bank will shift to the Data Center site only when the required certificates are submitted by the L1 bidder. In case L1 bidder is not able to provide certificates in given timelines, Bank has discretion to offer contract to the L2 bidder subject to matching the L1 price.</p>
2	<p>Annexure 2 – Eligibility Criteria D. Experience & Support Infrastructure 1.</p> <p>a) Bidder must have provided DC or DRC or Near DR / DC co-hosting facility to at least 20 Companies at DC co-hosting sites in India, b) Out of which there should be at least 4 credentials of Commercial Banks or BFSI in India who have co-hosted their DC or DRC or Near DR / DC with the service provider. c) Each of these 4 Commercial Banks / BFSI should have co-hosted minimum of 60 Racks or 1800 sqft. area in last 5 years of operations.</p>	<p>Annexure 2 – Eligibility Criteria D. Experience & Support Infrastructure 1.</p> <p>a) Bidder must have provided DC or DRC or Near DR / DC co-hosting facility to at least 20 Companies at DC co-hosting sites in India, b) Out of which there should be at least 4 credentials of Commercial Banks or BFSI in India who have co-hosted their DC or DRC or Near DR / DC with the service provider. c) Each of these 4 Commercial Banks / BFSI should have co-hosted minimum of 40 Racks or 1000 sqft. area in last 5 years of operations.</p>
3	<p>Additional clause for B. Financial and D. Experience & Support Infrastructure</p>	<p>In case of acquisition/ merger/ de merger, credentials related to Finance and Experience of the previous organization may be considered.</p>
4	<p>Annexure 11 - Project Scope & Technical Requirement F. Miscellaneous The Bank requires that the proposed Co-</p>	<p>Annexure 11 - Project Scope & Technical Requirement F. Miscellaneous The Bank requires that the proposed Co-hosting</p>

Sr No.	Clause in RFP	Clarifications/ Changes made
	hosting site facility provided to the Bank under this RFP must be owned premises or leased premises. In case of leased premises, an unexpired lease period must be for 20 years from the RFP Response due date.....	site facility provided to the Bank under this RFP must be owned premises or leased premises. In case of leased premises, an unexpired lease period must be for 15 years from the RFP Response due date.....
5	Annexure 11 - Project Scope & Technical Requirement G. Technical requirement 13. Proposed Caged area will have clear space area of 2700 sq. ft. (excluding cage) and will easily accommodate 90 racks (42U - 2ft X 3.5 ft X 7 ft)	Annexure 11 - Project Scope & Technical Requirement G. Technical requirement 13. Proposed Caged area will have clear space area of 4500 sq. ft. (excluding cage) and will easily accommodate 150 racks (42U - 2ft X 3.5 ftX 7 ft) OR Two proposed caged areas will have clear space area of 2700 sq. ft. (excluding cage) and will easily accommodate 90 racks (42U - 2ft X 3.5 ftX 7 ft) and 1800 sq. ft. (excluding cage) and will easily accommodate 60 racks (42U - 2ft X 3.5 ftX 7 ft)
6	Annexure 11 - Project Scope & Technical Requirement H. Technical requirement Out of the above mentioned 56 number of technical requirements in Clause G, bidder should have the below mentioned 32 number of technical requirements as 'Readily Available' and demonstrate their compliance to the Bank during site visit. Marks for these 32 points will be allotted after successful demonstration and validation during the site visit.	Annexure 11 - Project Scope & Technical Requirement H. Technical requirement for Site Visit Out of the above mentioned 56 number of technical requirements in Clause G, bidder should have the below mentioned 32 number of technical requirements as 'Readily Available' and demonstrate their compliance to the Bank during site visit. Marks for these 32 points will be allotted after successful demonstration and validation during the site visit. Proposed Site should be readily available for verification of technical parameters of RFP during site visit by the Bank. Site visit is tentatively to be conducted within 30 days from the date of bid submission.
7	Annexure 11 - Project Scope & Technical Requirement H. Technical requirement 11. Proposed Caged area will have clear space area of 1500 sq. ft. (excluding cage) and will easily accommodate 50 racks (42U - 2ft X 3.5 ftX 7 ft)	Annexure 11 - Project Scope & Technical Requirement H. Technical requirement 11. Proposed Caged area will have clear space area of 4500 sq. ft. (excluding cage) and will easily accommodate 150 racks (42U - 2ft X 3.5 ftX 7 ft) OR Two proposed caged areas will have clear space area of 2700 sq. ft. (excluding cage) and will easily accommodate 90 racks (42U - 2ft X 3.5 ftX 7 ft) and 1800 sq. ft. (excluding cage) and will easily accommodate 60 racks (42U - 2ft X 3.5 ftX 7 ft)

All other Terms & Conditions are same as per our RFP no. BCC:IT:PROC:113:04 dated 10th February 2021 for Selection of Service Provider for DC Site in co-hosting model.