

**BANK OF BARODA**  
**FACILITIES MANAGEMENT DEPARTMENT**  
 1st Floor, Baroda Corporate Centre,  
 C-26, G-BLOCK, BANDRA KURLA COMPLEX,  
 BANDRA (EAST), MUMBAI-400051

**CORRIGENDUM-1**  
**DATED: 27.11.2017**

With reference to our NIT dated 10.11.2017 issued for “**Appointment of consultant for providing comprehensive service including supervision of Renovation/ Up-gradation/ Modernization work of HVAC Plant at Bank of Baroda, Baroda Corporate Centre, Mumbai** and pre-bid meeting held on 22.11.2017. Following modifications have been made:

S.N	Page No.	Clause No./Ref.	Query/Suggestion	Clarification/Addendum
1	4	<b>Technical Bid II- Clause No.4/Supervision Stage/4.3</b>	Deployment of supervisor/engineer shall be periodically or regular.	Supervisor/Engineer shall be deployed during execution of the work. Periodic visit shall not be acceptable.
2	-	-	Duration for Completion of the Work/project i.e. <b><u>Renovation/ Up-gradation/ Modernization work of HVAC Plant at Bank of Baroda, Baroda Corporate Centre, Mumbai.</u></b>	The duration of the Project/Work i.e. <b><u>Renovation/ Up-gradation/ Modernization work of HVAC Plant at Bank of Baroda, Baroda Corporate Centre, Mumbai</u></b> shall be <b>SIX Months</b> from the date of LOI to the L-1 Bidder. <b><u>Renovation/ Up-gradation/ Modernization work of HVAC Plant at Bank of Baroda, Baroda Corporate Centre, Mumbai</u></b> shall be carried out only during non-working hours of the bank, i.e. during Night Hours, Weekly Off Days etc. However, if such periods are to be extended due to any reasons, the period shall be treated extended without any Financial implication.
3	-	-	Details of Existing HVAC Plant.	Refer Annexure-A of Corrigendum-I.
4	1	<b>Technical Bid I</b>	Department for submission of Bids	All submissions to be made on the following address: <b>General Manager, Facilities Management Department, Bank of Baroda, Baroda Corporate Centre, C-26, G Block, Bandra-Kurla Complex, Bandra East, 400051, Mumbai.</b>

**Note:**

- Bidders are advised to consider and confirm the above points while submitting the bids.
- The above shall be complementary in contents with the existing terms and conditions of the tender except otherwise explicitly superseded. All other terms and conditions of the tender shall remain unchanged.
- This Corrigendum – I shall form part of the tender i.e. contract agreement.
- The bidders have to submit “Unconditional TENDER”. Conditional bids are liable to be rejected. Sealed and signed copy of the tender to be submitted along with corrigendum-I.
- Last Date for Submission of Bids shall be 04.12.2017, till 15:00 Hrs. Technical Bids shall be opened on 04.12.2017 at 15:30Hrs.

**D. K. Namdeo**  
**GM & Head – FM & COA**

**Place: Mumbai**  
**Date: 27.11.2017**

*Seal & Sign of Bidder*

**ANNEXURE-A**

**Details of the Existing HVAC Plant installed at Bank of Baroda, Baroda Corporate Centre, Mumbai.**

The existing HVAC Plant consists of 03 Nos. Chiller Plant (Air Cooled) with screw type compressors of various capacities and supported by 27 nos Air Handling Units (AHUs) of variable capacities/CFM for circulation of cooled air in the building as mentioned in the table below:

<b>Sr. No.</b>	<b>Particulars</b>	<b>Units (nos.)</b>	<b>Capacity</b>	<b>Total Capacity</b>	<b>Type of Chillers</b>
1	Chiller no. 1	2	125TR	250 TR	Screw type Compressor
2	Chiller no. 2	1	80 TR	80 TR	Screw type Compressor
3	Chiller no. 3	2	125 TR	250 TR	Screw type Compressor
4	Air Handling Units	4	4000 CFM	16000 CFM	
		3	5000 CFM	15000 CFM	
		14	6000 CFM	84000 CFM	
		1	7100 CFM	7100 CFM	
		2	8000 CFM	16000 CFM	
		1	8700 CFM	8700 CFM	
		2	12000 CFM	24000 CFM	